

**ADDENDUM NO. 1**

To the Contract Documents for  
GA Terminal Site Improvements  
at  
Adirondack Regional Airport  
Saranac Lake, New York



---

Shawn Bray, P.E.  
License No. 071383

The following constitutes Addendum No. 1

Pages  
ADD 1-1 to ADD 1-3

Date  
January 26, 2012

Prepared By:

PASSERO ASSOCIATES  
100 Liberty Pole Way  
Rochester, New York 14604

**ADDENDUM NO. 1**  
**January 26, 2012**

Your attention is directed to the following changes in the Contract Documents for the GA Terminal Site Improvements Project. This Addendum is part of the Contract Documents in accordance with provisions included in Section GP-20 and acknowledged on page BID-8.

In the Contract Drawings:

**None**

In the Contract Document Book:

1. On page 33 10 00 – 3: In section 2.9, **Add** the following
  - B. Well pump piping shall be poly 200 psi, sized to meet the discharge of the pump
  - C. Snifter valve is not required.
  - D. Check valve shall be Boshart, or equal, sized for well pump piping
  - E. Locking device is not required.
  - F. Pitless adapter shall be Boshart, or equal
  - G. Safety rope, nylon, rated for well use

**END OF ADDENDUM**

To Acknowledge Receipt of this Addendum No. 1, Please Sign Below

---

**Please Print Name/Firm**

---

**Signature**

and **Return** Via Fax to:

Joanne Randall

Passero Associates

**FAX (585) 760-8539**

**PHONE (585) 325-1000**

Contract Documents for  
GA Terminal Site Improvements  
at  
Adirondack Regional Airport  
Saranac Lake, New York